










序号	报告编号	发布日期	结论	影像资料
79	GX-B1535/21-4-23299~23302	2023. 9. 19	所检项目合格。	
80	GX-B1520/20-4-23021	2023. 9. 19	综合判定 合格	
81	GX-B1520/20-4-23022	2023. 9. 19	综合判定 合格	


82	GX-B1310/21-4-23147	2023. 9. 22	符合标准要求	
83	GX-B1310/21-4-23148	2023. 9. 22	符合标准要求	
84	GX-B1328/20-4-23186	2023. 9. 25	本次共检绝缘手套2只，2只所检项目合格。	




85	GX-B1328/20-4-23187	2023. 9. 25	本次共检绝缘鞋2只，2只所检项目合格。	
86	GX-B1328/20-4-23188	2023. 9. 25	所检项目合格。	
87	GX-B1328/20-4-23182	2023. 9. 25	本次共检绝缘手套28只，28只所检项目合格。	

88	GX-B1328/20-4-23183	2023. 9. 25	本次共检绝缘鞋22只，22只所检项目合格。	
89	GX-B1304/21-4-23004	2023. 9. 25	综合判定：合格	
90	GX-B1520/20-4-23021	2023. 9. 19	综合判定 合格	

91	GX-B1520/20-4-23022	2023. 9. 19	综合判定 合格	
92	GX-B1535/21-4-23299~23302	2023. 9. 19	所检项目合格。	
93	GX-B1598/21-4-23013	2023. 9. 23	实测钢丝绳有效截面积损失百分比最大为4.95%，小于5%为正常。	




94	GX-B1598/21-4-23014	2023. 9. 23	实测钢丝绳有效截面积损失百分比最大为4.98%，小于5%为正常。	
95	GX-B1598/21-4-23015	2023. 9. 23	实测钢丝绳有效截面积损失百分比最大为4.92%，小于5%为正常。	
96	GX-B1598/21-4-23016	2023. 9. 23	实测钢丝绳有效截面积损失百分比最大为3.97%，小于5%为正常。	

97	GX-B1598/21-4-23017	2023. 9. 23	实测钢丝绳有效截面积损失百分比最大为2.83%，小于5%为正常。	
98	GX-B1598/21-4-23018	2023. 9. 23	实测钢丝绳有效截面积损失百分比最大为4.34%，小于5%为正常。	
99	GX-B1598/21-4-23019	2023. 9. 23	实测钢丝绳有效截面积损失百分比最大为3.57%，小于5%为正常。	

100	GX-B1598/21-4-23020	2023. 9. 23	实测钢丝绳有效截面积损失百分比最大为2.07%，小于5%为正常。	
101	GX-B1598/21-4-23021	2023. 9. 23	实测钢丝绳有效截面积损失百分比最大为1.71%，小于5%为正常。	
102	GX-B1598/21-4-23022	2023. 9. 23	实测钢丝绳有效截面积损失百分比最大为1.59%，小于5%为正常。	

103	GX-B1598/21-4-23023	2023. 9. 23	实测钢丝绳有效截面积损失百分比最大为1.91%，小于5%为正常。			
104	GX-B1598/21-4-23024	2023. 9. 23	实测钢丝绳有效截面积损失百分比最大为0.78%，小于5%为正常。			
105	GX-B1495/20-4-231824~231829	2023. 9. 26	本次共检高压开关柜6面，6面高压开关柜所检项目合格。			

106	GX-B1495/20-4-231830~231836	2023. 9. 26	本次共检高压开关柜7面，7面高压开关柜所检项目合格。			
107	GX-B1495/20-4-231837~231843	2023. 9. 26	本次共检高压开关柜7面，7面高压开关柜所检项目合格。			
108	GX-B1495/20-4-231844~231850	2023. 9. 26	本次共检高压开关柜7面，7面高压开关柜所检项目合格。			

109	GX-B1328/20-4-23180	2023. 9. 26	本次共检绝缘手套42只，42只所检项目合格。	
110	GX-B1328/20-4-23181	2023. 9. 26	本次共检绝缘鞋42只，42只所检项目合格。	
111	GX-B1328/20-4-23178	2023. 9. 25	本次共检绝缘手套50只，50只所检项目合格。	

112	GX-B1328/20-4-23179	2023. 9. 25	本次共检绝缘鞋50只，50只所检项目合格。	
113	GX-B1304/21-4-23005	2023. 9. 27	综合判定：合格。	
114	GX-B1321/20-4-23927~23929	2023. 9. 27	本次共检电力电缆3条，3条电力电缆所检项目合格。	

115	GX-B1312/20-4-23571	2023. 9. 27	所检项目合格。	
116	GX-B1380/20-4-23015	2023. 9. 27	所检项目合格	
117	GX-B1380/20-4-23016	2023. 9. 27	所检项目合格	

